



Unit 1: Reactor Water Level




Attachment II-1-1-1


Unit 1 Reactor Pressure




Compiled from the "Recorder Chart" (May 2011) by TEPCO



Narrow range




Wide range



Compiled from the "Transient Analysis Recording System" (May 2011) by TEPCO

Unit 1 Reactor Pressure Vessel (RPV) Temperature



Explanatory notes


TR-263-104

Color	Dot	Name of Measurement	Color	Dot	Name of Measurement
1	●	vessel flange	13	+	vessel downcomer
2	■	vessel steam	14	+	vessel above skirt joint
3	■	vessel below water level	15	+	vessel above skirt joint
4	■	vessel below water level	16	+	vessel skirt near joint
5	■	feedwater nozzle N2B-end	17	+	vessel bottom head
6	■	feedwater nozzle N2B-board	18	+	vessel bottom head
7	■	feedwater nozzle N2C-end	19	+	vessel skirt at mid flange
8	■	feedwater nozzle N2C-board	20	+	top control rod drive housing
9	■	vessel core	21	+	top control rod drive housing
10	■	vessel core	22	+	vessel head adjacent to flange
11	■	vessel downcomer	23	+	vessel head flange
12	■	vessel downcomer	24	+	vessel stud

An indication fault was found with the thermocouple for the vessel down-comer (No.11) when the reactor was reactivated after the periodic inspection in 2001. The cable was removed then from the recorder for that thermocouple. At that time, the recorders for No.11 and No.12 thermocouples were connected to each other with another cable. Because the thermocouple for No.11 was left unchanged to a new one, the same data had been kept recorded as the data of No.11 and that of No. 12 thereafter until March 11, 2011.

Compiled from the "Recorder Chart" (May 2011) by TEPCO

Unit 1 Temperatures at the Vessel Bottom




Temperature at the vessel bottom
No. 4, 5)

Attachment II -1-1-4

Explanatory notes

TR-260-20		Name of Measurement		Name of Measurement	
No	Color	Dot	No	Color	Dot
1	●	TE261-13A VALVE203-4A	7	■	TE261-14B VALVE203-3B
2	●	TE261-13C VALVE203-4C	8	■	TE261-14C VALVE203-3C
3	●	TE261-13B VALVE203-4B	9	■	TE261-14D VALVE203-3D
4	●	TE263-69P VESSEL BOTTOM	10	■	
5	●	TE263-69P VESSEL BOTTOM	11	■	
6	●	TE261-14A VALVE203-3A	12	■	



Unit 1 D/W Pressure



(Red) D/W Pressure

Compiled from the "Recorder Chart" (May 2011) by TEPCO

Unit 1 Temperatures around D/W HVH




Explanatory note

TR-1602-5		Name of Measurement		Name of Measurement	
No.	Color	Dot	No.	Color	Dot
1	■	●	13	■	+
2	■	●	14	■	+
3	■	●	15	■	+
4	■	●	16	■	+
5	■	●	17	■	+
6	■	●	18	■	+
7	■	●	19	■	+
8	■	●	20	■	+
9	■	●	21	■	+
10	■	●	22	■	+
11	■	●	23	■	+
12	■	●	24	■	+


Attachment II-1-1-6

Compiled from the "Recorder Chart" (May 2011) by TEPCO

Unit 1 Containment Atmosphere Monitoring System





Unit 1 Radiation Monitor of Stack



Compiled from the "Recorder Chart" (May 2011) by TEPCO

Radiation Dose Rates at Monitoring Posts (MP)




Radiation Dose Rates at Unit 1-3 Containment Atmosphere Monitoring System (CAMS)


No significant increase observed in the radiation dose rate.

<Unit 1>

(Red) Containment Atmosphere Monitoring System A (D/W)
(Green) Containment Atmosphere Monitoring System C (S/C)




(Red) Containment Atmosphere Monitoring System B (D/W)
(Green) Containment Atmosphere Monitoring System D (S/C)




<Unit 2>

(Red) Containment Atmosphere Monitoring System A (D/W)
(Green) Containment Atmosphere Monitoring System C (S/C)




(Red) Containment Atmosphere Monitoring System B (D/W)
(Green) Containment Atmosphere Monitoring System D (S/C)




<Unit 3>

(Red) Containment Atmosphere Monitoring System A (D/W)
(Green) Containment Atmosphere Monitoring System C (S/C)






(Red) Containment Atmosphere Monitoring System B (D/W)
(Green) Containment Atmosphere Monitoring System D (S/C)



Compiled from the "Recorder Chart" (May 2011) by TEPCO


Radiation Dose Rates at Unit 1-6 Main Exhaust Stack

No significant increase observed in the radiation dose.



Compiled from the "Recorder Chart" (May 2011) by TEPCO


Logic Flow of the Startup LOCA Signal Actuation



- Note 1: The startup LOCA signal here means the signal for activating the High Pressure Coolant Injection System (HPCI), Core Spray System (CS) and emergency DGs.
- Note 2: When the "Low-low reactor water level" or "High reactor containment vessel pressure" is detected, the detection circuit, relay circuit and logic circuit become electrified in that order, and if the condition X or Y is achieved then necessary power for the activation of each equipment will be supplied.

Compiled from the "Recorder Chart" (May 2011) by TEPCO

LOCA Signal Situation in Unit 1




LOCA signal was not sent out from any systems.

- Signalling
- No signalling




Unit 1 Main Steam Flow and APRM Output

Attachment II-1-1-11









3/11
At 14:47:50 “High main steam line flow” with A and C systems.
At 14:47:51 “High main steam line flow” with B and D systems.

(Based on the alarm typer at Unit 1)




The behavior of the decline of the main steam flow rate and the decline in the APRM output correlate to each other.




Compiled from the “Transient Analysis Recording System” (May 2011) by TEPCO

Unit 1 D/W Pressure, D/W Temperature, S/C Pressure and S/C Water Temperature


D/W pressure • S/C pressure (pressure difference with D/W pressure)




D/W temperature




S/C water temperature (A)



S/C water temperature (B)




Compiled from the "Recorder Chart" (May 2011) by TEPCO





※In an actual condition, two lines on the recorder chart indicating the temperatures at the same time are programmed to be recorded with a slight gap from each other to avoid the pointers clashing against one another, whilst the time difference on the chart above has been adjusted by deleting the gap.

Compiled from the "Recorder Chart" (May 2011) by TEPCO




(The condition of the connection of the IC back piping and PLP piping is based on construction approval documents, photographs and other other materials.)

Unit 1 Inlet Pressure of the Isolation Condenser (IC) Tank




Attachment II-1-1-14

Unit 1 Water Level of the Isolation Condenser (IC) Tank



Attachment II-1-1-15

Unit 1 Water Temperature of Isolation Condenser (IC) Tank




The temperature of the water within the IC tank of both channels A and B is rising due to the heat exchange with steam flowing in the IC pipe.

Explanatory notes


Name of Measurement		Unit		Date	
1	FUEL POOL TEMP UPPER	TEMP	TEMP	1E-104-1001	1E-104-1001
2	FUEL POOL TEMP LOWER	TEMP	TEMP	1E-104-1002	1E-104-1002
3	ISOLATION CONDENSER A OUTLET	TEMP	TEMP	1E-104-1003	1E-104-1003
4	ISOLATION CONDENSER B OUTLET	TEMP	TEMP	1E-104-1004	1E-104-1004
5	SHC A PUMP DISCHARGE	TEMP	TEMP	1E-104-1005	1E-104-1005
6	SHC B PUMP DISCHARGE	TEMP	TEMP	1E-104-1006	1E-104-1006
7	SHC A HX OUTLET	TEMP	TEMP	1E-104-1007	1E-104-1007
8	SHC B HX OUTLET	TEMP	TEMP	1E-104-1008	1E-104-1008
9	RCW OUTLET HX A	TEMP	TEMP	1E-104-1009	1E-104-1009
10	RCW OUTLET HX B	TEMP	TEMP	1E-104-1010	1E-104-1010
11	ISOLATION CONDENSER A SHELL	TEMP	TEMP	1E-104-1011	1E-104-1011
12	ISOLATION CONDENSER B SHELL	TEMP	TEMP	1E-104-1012	1E-104-1012
13	ISOLATION CONDENSER A OUTLET	TEMP	TEMP	1E-104-1013	1E-104-1013
14	ISOLATION CONDENSER B OUTLET	TEMP	TEMP	1E-104-1014	1E-104-1014
15	ISOLATION CONDENSER A SHELL	TEMP	TEMP	1E-104-1015	1E-104-1015
16	ISOLATION CONDENSER B SHELL	TEMP	TEMP	1E-104-1016	1E-104-1016
17	FUEL POOL COOLING HX OUTLET	TEMP	TEMP	1E-104-1017	1E-104-1017
18	FUEL POOL COOLING HX INLET	TEMP	TEMP	1E-104-1018	1E-104-1018
19	FUEL POOL COOLING HX OUTLET	TEMP	TEMP	1E-104-1019	1E-104-1019
20	FUEL POOL COOLING HX INLET	TEMP	TEMP	1E-104-1020	1E-104-1020
21	CONT SPRAY SYS A HX OUTLET	TEMP	TEMP	1E-104-1021	1E-104-1021
22	CONT SPRAY SYS B HX OUTLET	TEMP	TEMP	1E-104-1022	1E-104-1022
23	CONT SPRAY SYS C HX OUTLET	TEMP	TEMP	1E-104-1023	1E-104-1023
24	CONT SPRAY SYS D HX OUTLET	TEMP	TEMP	1E-104-1024	1E-104-1024

Compiled from the "Recorder Chart" (May 2011) by TEPCO


Unit 1 HPCI Turbine Inlet Pressure





Almost the same transition




Wide range






Unit 2: Reactor Water Level and Pressure



Compiled from the “Recorder Chart” (May 2011) by TEPCO




Attachment II-1-1-19

[0mm (Narrow range and wide range) = TAF+4,170mm (Fuel range)]

Compiled from the “Transient Analysis Recording System” (May 2011) by TEPCO

Unit 2 Reactor Pressure Vessel (RPV) Temperature




Attachment II-1-1-20

Explanation note

TR-2-3-89

No	Color	Dot	Name of Measurement
1	Blue	●	Feedwater nozzle N-4B temperature
2	Red	●	Feedwater nozzle N-4B temperature
3	Blue	●	Feedwater nozzle N-4D temperature
4	Blue	●	Feedwater nozzle N-4D temperature
5	Blue	●	CRD Housing upper part temperature
6	Blue	●	CRD Housing lower part temperature
7	Green	●	RPV Bottom head upper part temperature
8	Red	●	RPV Support skin upper part temperature
9	Blue	●	RPV Drain pipe temperature
10	Blue	●	RPV Head flange ambient temperature
11	Blue	●	RPV Head flange temperature
12	Blue	●	RPV Body flange temperature


Unit 2 Reactor Containment Vessel Nitrogen Gas Pressure



(Green) Reactor containment vessel nitrogen gas pressure

Compiled from the “Recorder Chart” (May 2011) by TEPCO


Unit 2 Drywell (D/W) Cooler HVH Temperature



Explanatory note

TRS-16-115 測定値		測定値		Object of Measurement		測定値	
1	●	2	●	Return air D/W cooler HVH-16A		12	●
3	○	4	○	Return air D/W cooler HVH-16B		13	○
5	+	6	+	Return air D/W cooler HVH-16C		14	+
7	△	8	△	Return air D/W cooler HVH-16D		15	△
9	▽	10	▽	Supply air D/W cooler HVH-16A		16	▽
11	●	12	●	Supply air D/W cooler HVH-16B		17	●
13	○	14	○	Supply air D/W cooler HVH-16C		18	○
15	+	16	+	Supply air D/W cooler HVH-16D		19	+
17	△	18	△	Supply air D/W cooler HVH-16E		20	△
19	▽	20	▽	RPV bellows seal area		21	▽
21	●	22	●	RPV bellows seal area		23	●
23	○	24	○	RPV bellows seal area		25	○
25	+	26	+	RPV bellows seal area		27	+
27	△	28	△	RPV bellows seal area		29	△
29	▽	30	▽	S/C gas temperature		31	▽
31	●	32	●	S/C gas temperature		33	●
33	○	34	○	S/C gas temperature		35	○
35	+	36	+	S/C gas temperature		37	+
37	△	38	△	Reserve		39	△
39	▽	40	▽	Electric penetration temperature		41	▽
41	●	42	●	Electric penetration temperature		43	●
43	○	44	○	Electric penetration temperature		45	○
45	+	46	+	Electric penetration temperature		47	+
47	△	48	△	Electric penetration temperature		49	△
49	▽	50	▽	Electric penetration temperature		51	▽


Unit 2 Containment Atmosphere Monitoring System



Unit 2 Operation of SRV

Attachment II-1-1-24

D628 Safety relief valve F, open




Opening-closing record of the safety relief valve F


No.	3/11 Time	SRV F Open	No.	3/11 Time	SRV Open
1	14:52:33	ON	26	15:11:02	ON
	14:52:40	OFF		15:11:11	OFF
2	14:53:18	ON	27	15:12:15	ON
	14:53:25	OFF		15:12:23	OFF
3	14:53:56	ON	28	15:13:41	ON
	14:54:04	OFF		15:13:49	OFF
4	14:54:33	ON	29	15:15:07	ON
	14:54:42	OFF		15:15:14	OFF
5	14:55:20	ON	30	15:16:47	ON
	14:55:29	OFF		15:16:54	OFF
6	14:56:12	ON	31	15:21:27	ON
	14:56:22	OFF		15:21:35	OFF
7	14:56:50	ON	32	15:28:08	ON
	14:56:59	OFF		15:28:16	OFF
8	14:57:32	ON	33	15:29:03	ON
	14:57:41	OFF		15:29:11	OFF
9	14:58:08	ON	34	15:29:55	ON
	14:58:17	OFF		15:30:03	OFF
10	14:58:44	ON	35	15:30:44	ON
	14:58:53	OFF		15:30:53	OFF
11	14:59:20	ON	36	15:31:33	ON
	14:59:29	OFF		15:31:42	OFF
12	14:59:57	ON	37	15:32:26	ON
	15:00:06	OFF		15:32:35	OFF
13	15:00:34	ON	38	15:33:15	ON
	15:00:43	OFF		15:33:24	OFF
14	15:01:10	ON	39	15:34:04	ON
	15:01:19	OFF		15:34:13	OFF
15	15:01:46	ON	40	15:34:53	ON
	15:01:56	OFF		15:35:01	OFF
16	15:02:22	ON	41	15:35:41	ON
	15:02:33	OFF		15:35:49	OFF
17	15:03:01	ON	42	15:36:28	ON
	15:03:11	OFF		15:36:37	OFF
18	15:03:42	ON	43	15:37:19	ON
	15:03:52	OFF		15:37:28	OFF
19	15:04:25	ON	44	15:38:07	ON
	15:04:35	OFF		15:38:15	OFF
20	15:05:10	ON	45	15:39:03	ON
	15:05:21	OFF		15:39:12	OFF
21	15:06:00	ON	46	15:39:52	ON
	15:06:10	OFF		15:40:00	OFF
22	15:06:52	ON	47	15:40:48	ON
	15:07:02	OFF		15:40:56	OFF
23	15:07:48	ON	48	15:41:47	ON
	15:07:58	OFF		15:41:56	OFF
24	15:08:51	ON	49	15:43:02	ON
	15:09:01	OFF		15:43:07	OFF
25	15:09:54	ON			
	15:10:04	OFF			

※There is no record of the valves A-E, valve G and valve H among the SRV


D623 Safety relief valve A, On




D624 Safety relief valve B, On




D625 Safety relief valve C, On




D626 Safety relief valve D, On




D627 Safety relief valve E, On



D629 Safety relief valve G, On



D630 Safety relief valve H, On




Compiled from the “Historical Data in the Process Computer System” (May 2011) by TEPCO

Between 14:52:33 and 15:43:07, the SRV (valve F) was repeatedly opened and closed for 49 times in total (counted based on the alarm typer record of Unit 2).


(Based on the data of the Unit 2 alarm typer and the alarm printer of the historical data in the process computer system)

Unit 2 PLR Pump Inlet Temperature




Compiled from the "Recorder Chart" (May 2011) by TEPCO


C020 Recirculation pump inlet temperature A1




C021 Recirculation pump inlet temperature A2



C022 Recirculation pump inlet temperature B1




C023 Recirculation pump inlet temperature B2




Compiled from the "Historical Data in the Process Computer System" (May 2011) by TEPCO


Unit 2 Main Steam Flow Rate and APRM Output




(Based on the Unit 2 alarm typer record)



The decline of the main steam flow
and the decline in the APRM output
correlate to each other.




Unit 2 Water Level of the Floor Drain Sump in D/W




(Red) Water level of the floor drain sump in D/W

Compiled from the "Recorder Chart" (May 2011) by TEPCO


Unit 2 Standby Gas Treatment System (SGTS) Exhaust Radiation Monitor



Unit 2 S/C Water Level




Compiled from the "Recorder Chart" (May 2011) by
TEPCO




Compiled from the "Historical Data in the Process Computer System" (May 2011) by TEPCO

Unit 2 Decrease in Water Temperature in S/C due to Cooling Water



In case of S/C filled with water



S/C with damages




Unit 2 RCIC Pump Discharge Flow Rate etc.




(Compiled from the records of "Alarm Taper" (May 2011), "Process Computer System Alarm Printer" (May 2011), "Shift Operator's Logbook" (May 2011) and "Shift Operator's Logbook" (May 2011) by TEPCO


P750 RCIC pump discharge pressure



P751 RCIC pump discharge flow rate




B024 RCIC system flow




It is estimated that the RCIC continued to be in operation while unable to control flow rate.


P752 RCIC turbine rotation speed



R705 RCIC activation signal




D648 RCIC turbine activation



At 15:43:07
RCIC turbine activation signal OFF
15:43:08
RCIC activation signal stopped

(Based on the Unit 2 alarm typer)


Compiled from the "Historical Data in the Process Computer System" (May 2011) by TEPCO







Unit 3 Reactor Water Level

(Red) Reactor water level (narrow range)

At 15:25:02
High reactor water level → RCIC stopped
(Based on Unit 3 alarm typer record)



Compiled from the “Recorder Chart” (May 2011) by TEPCO




(Note)

Regarding the data recorded by the Unit 3 Transient Analysis Recording System, TEPCO announced that data was interrupted for approximately 30 minutes from 14:59 on March 11, 2011, as a result of cross-checking against the record of other charts, and thus, the times for the data thereafter are estimated.

Compiled from the “Transient Analysis Recording System” (May 2011) by TEPCO

Unit 3 Reactor Pressure Vessel (RPV) Temperature



RPV Drain temperature (No.9)

RPV Bottom head temperature (No.13)


CRD Housing upper part Temperature (No.5)

Thermocouple location

Explanatory note

TRS-2-3-89

No.	Color Dot	Name of Measurement	No.	Color Dot	Name of Measurement
1	●	RPV Feedwater nozzle N4B	13	+	RPV lower part head temperature
2	●	RPV Feedwater nozzle N4B	14	+	RPV wall in the vicinity of flange
3	●	RPV Feedwater nozzle N4D	15	+	The bottom part of RPV situated above the vessel support skirt
4	●	RPV Feedwater nozzle N4D	16	+	The wall of RPV under the feedwater nozzle
5	●	CRD Housing upper part	17	+	The bottom of the supporting skirt of flange
6	●	CRD Housing lower part	18	+	
7	●	RPV Bottom head upper part	19	Y	
8	●	RPV Support skirt upper part	20	Y	
9	○	RPV Drain	21	Y	
10	○	RPV Head	22	Y	
11	○	RPV Head flange	23	Y	
12	○	RPV Body flange	24	Y	




Attachment II-1-1-35

※ There is a possibility that the time on the recorder chart was about 7 minutes ahead of the actual time.

Compiled from the “Recorder Chart” (May 2011) by TEPCO



Unit 3 Reactor Containment Vessel Nitrogen Gas Pressure



(Red) Reactor containment vessel nitrogen gas pressure

Compiled from the "Recorder Chart" (May 2011) by TEPCO

Unit 3 Air Temperature Supplied by D/W HVH



Air temperature supplied by containment vessel air conditioning unit (No.7~No.10)

Air temperature supplied by containment vessel air conditioning unit (No.6)


Explanatory note

TRS-16-115				Unit 3			
Input		Store No.		Input		Switch Set	
No.	Color	Instrument	Unit	No.	Color	Instrument	Unit
1	●	TE-16-114A	Reum air temperature to DW HVH	13	●	TE-16-114N	Temperature of the reactor bellows seal
2	●	TE-16-114B	Reum air temperature to DW HVH	14	●	TE-16-114P	Temperature of the reactor bellows seal
3	●	TE-16-114C	Reum air temperature to DW HVH	15	●	TE-16-114R	Temperature of the reactor bellows seal
4	●	TE-16-114D	Reum air temperature to DW HVH	16	●	TE-16-114T	S/C gas temperature
5	●	TE-16-114E	Reum air temperature to DW HVH	17	●	TE-16-114U	S/C gas temperature
6	●	TE-16-114F	Reum air temperature to DW HVH	18	●	TE-16-114V	S/C gas temperature
7	●	TE-16-114G	Reum air temperature to DW HVH	19	●	TE-16-114W	S/C gas temperature
8	●	TE-16-114H	Reum air temperature to DW HVH	20	●	TE-16-114X	S/C gas temperature
9	●	TE-16-114I	Reum air temperature to DW HVH	21	●	TE-16-114Y	S/C gas temperature
10	●	TE-16-114J	Reum air temperature to DW HVH	22	●	TE-16-114Z	S/C gas temperature
11	●	TE-16-114K	Reum air temperature to DW HVH	23	●	TE-16-114AA	S/C gas temperature
12	●	TE-16-114L	Reum air temperature to DW HVH	24	●	TE-16-114AB	S/C gas temperature

Compiled from the "Recorder Chart" (May 2011) by TEPCO


Unit 3 Containment Atmosphere Monitoring System

(Red) Containment atmosphere monitoring system A (D/W)
(Green) Containment atmosphere monitoring system C (S/C)



Both indicate lower limit values

(Red) Containment atmosphere monitoring system B (D/W)
(Green) Containment atmosphere monitoring system D (S/C)




Unit 3 Main Stack Radiation Monitor

(Based on the Unit 3 alarm typer)

(Red) Main stack radiation monitor (Ionization chamber)

On March 11 at
14:47, SGTS
was activated

(Red) Main stack radiation monitor (Scintillation type)A
(Green) Main stack radiation monitor (Scintillation type)B



Attachment II-1-1-39


Compiled from the "Recorder Chart" (May 2011) by TEPCO

Unit 3 Operation of SRV

Opening-closing record of the safety relief valve C				
No.	3/11 Time	SRV C open	No.	SRV C open
1	14:51:50	On	28	15:07:58 On
2	14:51:55	Off	29	15:08:05 Off
3	14:52:29	On	30	15:08:39 On
4	14:52:35	Off	31	15:08:46 Off
5	14:53:03	On	32	15:09:55 On
6	14:53:11	Off	33	15:10:03 Off
7	14:53:56	On	34	15:11:09 On
8	14:54:04	Off	35	15:11:16 Off
9	14:54:48	On	36	15:12:01 On
10	14:54:56	Off	37	15:12:07 Off
11	14:55:21	On	38	15:13:32 On
12	14:55:29	Off	39	15:13:39 Off
13	14:55:53	On	40	15:14:43 On
14	14:56:01	Off	41	15:14:49 Off
15	14:56:26	On	42	15:15:54 On
16	14:56:34	Off	43	15:16:00 Off
17	14:57:00	On	44	15:17:17 On
18	14:57:07	Off	45	15:17:22 Off
19	14:57:33	On	46	15:19:01 On
20	14:57:41	Off	47	15:19:06 Off
21	14:58:06	On	48	15:25:58 On
22	14:58:14	Off	49	15:26:03 Off
23	14:58:39	On	50	15:27:19 On
24	14:58:47	Off	51	15:27:24 Off
25	14:59:13	On	52	15:28:17 On
26	14:59:21	Off	53	15:28:23 Off
27	14:59:47	On	54	15:30:02 On
	14:59:55	Off		15:30:09 Off
	15:00:21	On		15:30:51 On
	15:00:29	Off		15:30:58 Off
	15:00:56	On		15:31:39 On
	15:01:04	Off		15:31:50 Off
	15:01:30	On		15:32:32 On
	15:01:38	Off		15:32:45 Off
	15:02:04	On		15:33:27 On
	15:02:12	Off		15:33:40 Off
	15:02:39	On		15:34:23 On
	15:02:46	Off		15:34:37 Off
	15:03:12	On		15:35:21 On
	15:03:20	Off		15:35:36 Off
	15:03:46	On		15:36:19 On
	15:03:54	Off		15:36:36 Off
	15:04:21	On		15:37:20 On
	15:04:29	Off		15:37:36 Off
	15:04:56	On		15:38:20 On
	15:05:03	Off		15:38:40 Off
	15:05:30	On		15:39:26 On
	15:05:38	Off		15:39:46 Off
	15:06:06	On		15:40:33 On
	15:06:14	Off		15:40:54 Off
	15:06:42	On		15:41:39 On
	15:06:50	Off		15:42:02 Off
	15:07:19	On		15:42:48 On
	15:07:26	Off		15:43:12 Off

(Based on the Unit 3 alarm typer)

Compiled from the "Transient Analysis Recording System" (May 2012) by TEPCO




- Between 14:41:50 and 15:43:12, the SRV (Valve C) was repeatedly opened and closed 54 times in total (based on the Unit 3 alarm typer record).
- The transient analysis recording system data is missing for approximately 30 minutes from 14:59 and the records regarding the operations of SRV before and after this time period correspond with the records on the alarm typer.
- The data of the contact point D, which includes the operation record of SRV, on the alarm typer contains only up to 15:43:45, and there is no record of the operation of valves G and A that started the opening-closing operation after 15:50.

Valve G worked 8 times

(*)With the Unit 3 transient analysis recording system data, only the operations of valves A, C, E and G among the SRV are recorded)

(Note)
Regarding the data recorded by the Unit 3 Transient Analysis Recording System, TEPCO announced that data was interrupted for approximately 30 minutes from 14:59 on March 11, 2011, as a result of cross-checking against the record of other charts, and thus, the times for the data thereafter are estimated.

Unit 2 Main Steam Flow Rate and APRM Output



3/11

14:47:00 Earthquake trip (C)

Reactor automatic scram (A)

14:47:04 Earthquake trip (D)

Reactor automatic scram (B)

14:47:58

Main steam isolation valve,
Isolation signal

Main steam flow rate, high (A•C)

Main steam pressure, low (A)

Main steam line leak detection,
high (A•C)

(Based on the Unit 3 alarm typer)

14:48 Main steam isolation
valve, open OFF (completely
closed)


14:48:11

Main steam flow rate, high (B•D)


Main steam pressure, low (B)

Main steam line leak detection,
high (B•D)


Analogue PIDA000 APRM-A




Analogue PIDA001 APRM-B




Analogue PIDA002 APRM-C




Analogue PIDA003 APRM-D




Analogue PIDA004 APRM-E




Analogue PIDA005 APRM-F




Analogue PIDA310 Main steam flow rate B



Analogue PIDA311 Main steam flow rate C




Analogue PIDA312 Main steam flow rate D



The decline of the main steam
flow rate and the decline in the
APRM output correlate to each
other.

Unit 3 PLR Pump Inlet Temperature




(Red) PLR pump A inlet temperature
(Green) PLR pump B inlet temperature

At 14:59


The water level change rate for the D/W floor drain sump shows the value, far exceeding its upper limit.

Unit 3 Reactor Water Level and Reactor Pressure



Attachment II-1-1-44

Compiled from the "Recorder Chart" (May 2011) by TEPCO



The reactor pressure was indicated lower than 0.69MPa gage.

Unit 3 Shift Operators' Logbook

Attachment II-1-1-45


Saturday, March 12, 2011

1/

		Contents
	20:27	AM panel, D/W pressure, S/C pressure, S/C water level indicator. No power.
	20:36	No power for the reactor water level indicator. Final data - wide range Channel A: 1,350mm, fuel range Channel A: +400mm
	20:57	Water supply controller A - power "OFF"
		PLR controller A - power "OFF"
		ECCS recorder - power "OFF"
	21:30	Site PI indication: D/W pressure 170kPa
	3/13	
	1:45	D/D FP, diesel oil supply, 70 ↑ 110L. Suction pressure: 0MPa. Discharge: 0.42MPa
	2:42	HPCI stopped. Reactor pressure: 0.58MPa
	2:45	SRV did not open. Reactor pressure: 0.8MPa
	2:55	SRV did not open. Reactor pressure: 1.3MPa
	3:05	D/D FP, the fire pump injected into reactor. MO-10-27B. 15% open. There seemed a flowing sound at 70%. Suction pressure: 0 ↑ 0.14MPa. Discharge: 0.4 ↑ 0.61MPa
	3:35	HPCI FIC display light turned off.
	3:37	RCIC Vac pump did not become activated.
	3:39	HPCI AOP stopped.
	3:51	R × water level indicator (W). Indicator's power ON. -3600mmR
		R × water level indicator (fuel range). Indicator's power ON. -1600mm. Reactor pressure: 5MPa. A possibility of TAT
	4:04	R × water level indicator (fuel range). -1600mm. Reactor pressure: 5.6MPa.
	4:06	HPCI condensed water pump - power OFF.
	4:52	D/W vent valve, AO-205, temporary power outlet ON. Valve opening confirmed locally as fully closed. Cylinder pressure: 0
	5:08	S/C spray began. MO-10-25B closed.
	5:08	RCIC manually activated/Stop valve closed. RCIC stop valve reset - did not work.
	5:10	Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness. Complete loss of water supply.
	5:16	DTr pump - Megger test finished. No water exposure. Confirmation of usability.

Compiled from the "Shift Operators' Logbook" (May 2011) by TEPCO

Unit 3 Reactor Pressure




Reactor pressure increased before it reached the resetting value of the safety relief valve function of the SR valve.

The reactor pressure shows nearly 65 times of rise and fall (when the pressure indicates around 7.4MPa gage, drops sharply with a V-shape to nearly 7.0MPa gage and then rises again), which was influenced by the SRV opening-closing operation by the safety relief functions.


※In order to make the chart clearer, a red supplementary line for each 7.4MPa gage and 7.0MPa gage has been made.

Compiled from the "Recorder Chart" (May 2011) by TEPCO

Unit 3 Structure of the SRV




Unit 3 Reactor Pressure



※In order to make the chart clearly visible, actual times have been shown on the chart and a new line has been added to the line of 7.4MPa gage.


Unit 3 Standby Gas Treatment System (SGTS) Radiation Monitor

(Based on the Unit 3 alarm typer)




Compiled from the "Recorder Chart" (May 2011) by TEPCO

Unit 3 S/C Water Level




Compiled from the "Recorder Chart" (May 2011) by TEPCO

Unit 3 Analysis Results of the Reactor Pressure and D/W Pressure




(Note) D/W pressure at 22:00 on March 12, 2011, is recorded as “0.1700MPa abs” on the Unit 3 plant parameters, whereas in the memo by the Operation team at the Daiichi NPS ERC it is written as “270kPa abs D/W (at the site)”.




Compiled from the “Investigation on the influence of the thermal stratification of the retained water in suppression chamber on the reactor containment vessel pressure” (Materials 3 from the 7th Hearing Session regarding technical findings for the TEPCO Fukushima Daiichi Nuclear Power Station accident) (February 1, 2012) by JENES

Unit 3 Containment Vessel Temperature



Explanatory note


1 CRD Housing ambient temperature	4 RPV Bellow seal area
2 CRD Housing ambient temperature	5
3 RPV Bellow seal area	6



Attachment II-1-1-52

Compiled from the "Recorder Charts" (May 2011) by TEPCO

Unit 3 Reactor Water Level and RCIC Operation



(Red) Reactor water level (narrow range)

Tsunami
Earthquake
3/11

15:25:02


High reactor water level → RCIC stopped

(Based on Unit 3 alarm typer)



Compiled from the “Recorder Chart” (May 2011) by TEPCO

Analogue PIDA300 Reactor water level (N/R/A)




0mm (narrow range)
= TAF + 4,170mm (fuel range)

Earthquake

(Note)

Analogue PIDA303 Reactor water level (W/R/A)



Earthquake

At 15:05:39

RCIC turbine activated

At 15:06

RCIC injection valve “Open”

RCIC system flow rate 25.2 ℓ/s


(Based on the Unit 3 alarm typer)

(Note) Regarding the data recorded by the Unit 3 Transient Analysis Recording System, TEPCO announced that data was interrupted for approximately 30 minutes from 14:59 on March 11, 2011, as a result of cross-checking against the record of other charts, and thus, the times for the data thereafter are estimated.

Compiled from the “Transient Analysis Recording System” (May 2011) by TEPCO

Unit 3 Reactor Water Level, RCIC Pump Discharge Pressure etc.

(Red) Reactor water level (narrow range)



Analogue PIDA751 RCIC Pump discharge pressure

MPa

Water level (mm)

Analogue PIDA750 RCIC Pump discharge pressure

l/s

Analogue PIDA752 RCIC Turbine rotation speed

rpm

Analogue PIDA753 RCIC Flow controller

% output

Analogue PIDA754 RCIC Flow controller

% output

Attachment II-1-1-54

Compiled from the "Recorder Chart" (May 2011) by TEPCO

At 16:03
RCIC manually activated
After this, it was operated while
controlling the flow rate.

Compiled from the "Transient Analysis Recording System" (May 2011) by TEPCO

Response at the Unit 1 and the transition of indicated values shown by instrumentation devices

12th at 15:36
hydrogen gas explosion
occurred at R/B.

Water injection

12th at 4:00

12th at 14:53

Alternative water injection



This suggests the possibility that there was a water injection line configured and a fire pump was in operation to inject water. It does not necessarily mean that water was actually injected into the nuclear reactor.


Manual operation to
open the SRVManual operation to
open the reactor
containment vessel
vent valve

12th at 14:00




This suggests a possibility of the operation to open the valve required for the reactor containment vessel vent. For the implementation of the reactor containment vessel vent, however, the valve has to be kept open and also the rupture disc has to be ruptured, in addition to the opening operation of the vent valve.



Indicated value of reactor water level (fuel range) (mm)



Indicated value of reactor pressure indicator (MPa gage)



Each indicated value of D/W pressure indicator and S/C pressure indicator (MPa abs)

Monitoring post dose rate (μ Sv/h)

※The following radiation dose rates have also been measured in the vicinity of the main gate

On 12 March: 10:20, 180.2; 10:30, 385.5; 10:40, 162.9; 11:30, 35.8; 12:00, 23.2; 2:10, 48.2 (unit: μ Sv/h)

Response at the Unit 2 and the transition of indicated values shown by instrumentation devices

Water injection14th at 12:30
RCIC stopped14th
at 19:57

Whilst this suggests a possibility that the RCIC was in operation, it does not necessarily mean that the RCIC was functioning normally and water was being injected into the

Alternative water injection




This suggests the possibility that there was a water injection line configured and a fire pump was in operation to inject water. It does not necessarily mean that water was actually injected into the nuclear reactor.

Manual operation to open the SRV14th
at 16:34


This suggests a possibility that the operation to open the SRV were conducted. However, even if the operation to open the SRV was conducted, it is not clear as to whether the valve was kept open.

Manual operation to open the reactor containment vessel vent


Indicated value of reactor water level (fuel range) (mm)





Indicated value of reactor pressure indicator (MPa gage)



Each indicated value of D/W pressure indicator and S/C pressure indicator (MPa abs)



Indicator value of CAMS (Sv/h)

Monitoring post dose rate (μ Sv/h)


Compiled from the "Plant Related Parameters" (May 2011) etc. by TEPCO

Response at the Unit 3 and the transition of indicated values shown by instrumentation devices



14th at 11:01
Hydrogen gas explosion occurred at R/B

Water injection



Whilst this suggests a possibility that the HPCI was in operation, it does not necessarily mean that the HPCI was functioning normally and water was being injected into the nuclear reactor


This suggests the possibility that there was a water injection line configured and a fire pump was in operation to inject water. It does not necessarily mean that water was actually injected into the nuclear reactor

Manual operation to open the SRV




This suggests a possibility that the operation to open the SRV were conducted. However, even if the operation to open the SRV was conducted, it is not clear as to whether the valve was kept open.

Manual operation to open the reactor containment vessel vent




This suggests a possibility of the operation to open the valve required for the reactor containment vessel vent. For the implementation of the reactor containment vessel vent, however, the valve has to be kept open and also the rupture disc has to be ruptured, in addition to the opening operation of the vent


Indicated value of reactor water level (fule range) (mm)





Indicated value of reactor pressure indicator (MPa gage)



Each indicated value of D/W pressure indicator and S/C pressure indicator (MPa abs)




Indicator value of CAMS (Sv/h)


Monitoring post dose rate (μ Sv/h)

Compiled from the "Plant Related Parameters" (May 2011) etc. by TEPCO

Errors with Reactor Pressure Indicator

Normal condition


In the case where the water level in the reference leg or in the reference leg line lowers.




Normal condition

Errors with Reactor Water Level Indicator

Attachment II-1-3




Converts the differential pressure between the reactor vessel line pressure and reference leg line pressure into water level



Converts the differential pressure between the reactor vessel line pressure and reference leg line pressure into water level


※Each of the reactor vessel line pressure and reference leg line pressure is in absolute pressure.

①In the case where the reference water head or the water level in the reference leg line lowers.



(Reference) In the case where the water level rises in a normal condition


Converts the differential pressure between the reactor vessel line pressure and reference leg line pressure into water level




Converts the differential pressure between the reactor vessel line pressure and reference leg line pressure into water level

※Each of the reactor vessel line pressure and reference leg line pressure is in absolute pressure.

② In the case where the reactor water level falls below the inlet of the reactor vessel line




③ When ① and ② occur simultaneously




Unit 1 and Unit 3 Hydrogen Explosion Images

【Unit 1】




【Unit 3】



Images provided by Fukushima Central Television ※All rights reserved


Damaged Condition of Unit 1 R/B 5th Floor

【North wall】




Photographed by the Ministry of Defense, March 27, 2011

【East wall】




Photographed by the Ministry of Defense, March 27, 2011



Explanatory note

	: Complete collapse
	: Ceiling collapse


【West wall】



Photographed by the Ministry of Defense, March 27, 2011


Bending damage

【South wall】




Photographed by the Ministry of Defense, March 27, 2011

Main Causes of Hydrogen Generation inside the R/B



Amount of Hydrogen Generated at Unit 1




Attachment II-2-4




Note 1: The lower limit of the mixing ratio of hydrogen that could cause an explosion is set relatively high as 18.3%

Note 2: It is hypothesized that the temperature inside the R/B is 30°C and the atmospheric pressure, and the hydrogen density in this case is set as 0.08109kgm^3 .


Possible Locations of Hydrogen Leakage from Containment



Damaged Condition of Unit 2 R/B 5th Floor



【Opening part of the blowout panel】









Locations of Seismic Observation Recorders within the Fukushima Dai-ichi Nuclear Power Station

Maximum acceleration recorded by the seismic observation recorder at the occurrence of the explosion at Unit 1, Unit 3 and Unit 4 R/B (Gal)

	Unit 1 Explosion March 12 at 15:36			Unit 3 Explosion March 14 at 11:01			Unit 4 Explosion March 15 at 6:12		
	South-north direction	East-west direction	Vertical direction	South-north direction	East-west direction	Vertical direction	South-north direction	East-west direction	Vertical direction
Observation point A	81	52	120	14	15	21	2	2	2
Observation point B	284	129	138	45	18	28	4	3	3
Observation point C	2,320※	2,392※	1,956	115	158	490	11	9	6
Observation point D	102	91	231	36	51	173	6	7	11
Observation point E	39	22	26	26	24	30	5	5	11

※This value is only for information as it was out of range (2,000Gal) of the sensor. 値。







Accelerogram at the Unit 1 explosion (South-north direction)

Compiled from the data and materials created by TEPCO


【Observation point A】




【Observation point B】




【Observation point C】 ※This value is only for information as it was out of range (2,000Gal) of the sensor.



【Observation point D】




【Observation point E】




Accelerogram at the Unit 1 explosion (East-west direction)

Compiled from the data and materials created by TEPCO


【Observation point A】




【Observation point B】




【Observation point C】



【Observation point D】




【Observation point E】




Accelerogram at the Unit 1 explosion (Vertical direction)

Compiled from the data and materials created by TEPCO


【Observation point A】




【Observation point B】




【Observation point C】



【Observation point D】




【Observation point E】




Accelerogram at the Unit 3 explosion (South-north direction)

Compiled from the data and materials created by TEPCO


【Observation point A】




【Observation point B】




【Observation point C】



【Observation point D】




【Observation point E】




Accelerogram at the Unit 3 explosion (East-west direction)

Compiled from the data and materials created by TEPCO


【Observation point A】




【Observation point B】




【Observation point C】



【Observation point D】








【Observation point E】








Accelerogram at the Unit 3 explosion (Vertical direction)

Compiled from the data and materials created by TEPCO








Accelerogram at the Unit 4 explosion (South-north direction)

Compiled from the data and materials created by TEPCO



Accelerogram at the Unit 4 explosion (East-west direction)


Compiled from the data and materials created by TEPCO



Accelerogram at the Unit 4 explosion (Vertical direction)

Compiled from the data and materials created by TEPCO

Damaged Condition of Unit 3 R/B




Damaged Condition of Unit 3 R/B

【West wall】




Photographed by the Ministry of Defense, March 27, 2011

【4th Floor】



Explanatory notes	
	: Complete collapse
	: Partly collapse
	: Surface damage

【North wall】




Photographed by the Ministry of Defense, March 27, 2011

【South wall】



Photographed by the Ministry of Defense, March 27, 2011

【East wall】



Photographed by the Ministry of Defense, March 27, 2011


Damaged Condition of Unit 3 R/B

【West wall】




Photographed by the Ministry of Defense, March 27, 2011

【3rd Floor】



Explanatory notes
 : Surface damage

【North wall】




Photographed by the Ministry of Defense, March 27, 2011

【South wall】




Photographed by the Ministry of Defense, March 27, 2011

【East wall】



Photographed by the Ministry of Defense, March 27, 2011

Amount of Hydrogen Generated in Unit 3 and Unit 4



The amount of hydrogen assumed to be generated at Unit 3

<Results of MAAP analysis>

Over 600kg of hydrogen was generated by just after 12:00 on March 13.
 Furthermore, nearly 800kg of hydrogen in total was generated by midnight on March 15.


<Results of MELCOR analysis (operator's analysis 2) >

About 700kg of hydrogen was generated by 12:00 on March 13, and thereafter another 250kg was generated by midnight on March 15.
 → It is hypothesized that at least the estimated amount of approximately 800kg of hydrogen was generated in Unit 3.



Note 1: The lower limit of the mixing ratio of hydrogen that could cause an explosion is set relatively high as 18.3%

Note 2: It is hypothesized that the temperature inside each R/B is 30°C and the atmospheric pressure, and the hydrogen density in this case is set as 0.08109kg/m³.


【5th Floor】



Photographed by the Ministry of Defense, March 27,
2011



Photographed by the Ministry of Defense, March 27, 2011




-  : Complete collapse
-  : Partly collapse
-  : Exhaust duct
-  : Exhaust port
-  : Connection points to the lower floor

Compiled from data and materials by TEPCO


Damaged Condition of Unit 4 R/B

【North wall】




Photographed by the Ministry of Defense, March 27, 2011

【East wall】



Photographed by the Ministry of Defense, March 27, 2011


【4th Floor】



Explanatory notes


- Complete collapse
- Partly collapse
- Surface damage
- Exhaust duct
- Exhaust port
- Connection points to the lower floor
- Connection points to the upper floor

【West wall】



Photographed by the Ministry of Defense, March 27, 2011

【South wall】




Photographed by the Ministry of Defense, March 27, 2011

The floor surface right below the severely damaged floor on the 5th floor was distorted downward and a number of debris, which was assumed to be the wreckage of exhaust duct, were found.

Exhaust duct was smashed to the level that no original shape was visible, and the floor of the 4th floor was sinking towards the 3rd floor due to the explosion.

Damaged Condition of Unit 4 R/B

【North wall】




Photographed by the Ministry of Defense, March 27, 2011

【East wall】




Photographed by the Ministry of Defense, March 27, 2011

【3rd Floor】




Complete collapse	Exhaust port
Surface damage	Connection points to the lower floor
Exhaust duct	Connection points to the upper floor
Exhaust port	

【West wall】





Photographed by the Ministry of Defense, March 27, 2011

【South wall】



Photographed by the Ministry of Defense, March 27, 2011

【① Diagram from the East side】



Compiled from the “Fukushima Nuclear Accidents Investigation Report (Interim)” (December 2011) by TEPCO

Possible Inflow Pass of Hydrogen from Unit 3 to Unit 4

【② Diagram from the West side】

